




(iv) 100mts & above in Height	900 lpm	2850 lpm	maintain not less than 3.5kg at the top most or remote point.
10.	<b>Automatic Sprinkler System</b> to be provided for - All Educational Bldgs having height more than 30 Mtrs, Basement, ground All Parking including all educational building passage area covered by sprinkler system.		
11.	<b>Garbage chute</b> if any, shall be provided with <b>independent Sprinkler system</b> at each garbage inlet point of the chute pipe.		
12.	i) <b>MCP (Manual Call Points) and PA (Public Address ) Communication System</b> with Talk Back facility to be provided near to the all staircase (Not allowed in Fire Ducts or Staircases) ii) Life Guard & C.C.T.V. surveillance camera system to be provided to the entire premises of Swimming Pool area & Educational Bldg. iii) Public address system to be provided for Educational Eldg or each floor of Educational Bldg. for the emergency evacuation purpose.		
13.	i) <b>Minimum Three Staircases</b> (apart) to be provided. Two enclosed Fire Escape Staircase of Fire Tower Type to be provided with Double Leaf Fire Resistance Doors Assembly (with frame & accessories) of min 120 mins. According the width of staircase (45mm thick) to be provided for all Indoor assembly hall/Yoga/Kabbaddi hall area and Commercial bldgs to install Metal F. R. Door of CBRI / IPIRTI approved. This fire staircase shall be treated for use of inhabitants during fire and other emergencies and will not be taken into any other use, not even for installation of firefighting system, etc ii) <b>Handrail to be provided for all Staircase of the Educational Building.</b>		
14.	<b>Fire Escape Staircase</b> to be provided with Pressurization System, for Bldgs above 60 mtrs		
15.	All Bldgs above 60 mtrs and Starred Hotels, Malls, Multiplexes, Hospitals above 50 beds to be provided with <b>Fire Sealant material</b> of 2 hours rating at every floors at the point of Electric cables and other pipes etc passing through such floors or walls openings, etc		
16.	Hotel bldgs above 24 mtrs, Hospital bldgs above 15 mtrs, other Fully Commercial Bldgs above 24 mtrs, Residential Bldgs above 45 mtrs and Malls, Multiplexes irrespective of their height to provide <b>Fire Retardant Paint/Coat</b> (DRDO approved) for Electrical Cables.		
17.	<b>Automatic Fire Suppression Systems</b> to be provided for Electrical Panels.		
18.	Among the total Lifts provided, for Bldgs. upto 36 mtrs height, minimum one Lift to be Fire Lift of capacity 545 kgs (8 persons) area not less than 1.43 Sq. mtrs., Bldgs. between 36 Mtrs to 70 Mtrs in height Fire cum Stretcher Lift Capacity 884 Kgs. (13 persons) area not less than 2.06 Sq. Mtrs., Fire cum Stretcher Lift cap.1020 Kgs. (15 Persons) area no less than 2.35 Sq. mtrs. Should be provided in the Fire Tower For Bldgs. Height above 70 mtrs. These lifts shall have Fireman's switch and Talk back Facility emergency communication system.		
19.	<b>Refuge Area</b> of minimum 1/4th of the maximum floor area to be provided in front & conspicuously marked for identification located after 24 mtr, 39 mtr and every 5th floor thereafter. Refuge Area parapet wall and railings to be painted in red colour and a bold 'Fire Refuge Area" Board of min. 5ft x 3 ft painting prominently to be displayed. Fire Resistance Door (with frame & accessories) of min 120 mins (45mm thick) to be fitted for Refuge Area.		
20.	a) <b>Basement/Lower Parking</b> should have proper Mechanical Smoke Extraction & Dewatering pump Arrangements to prevent smoke and water logging. b) <b>Mirror</b> should be provided all Basement/Lower/Ground/Upper Parking Level's blind turn appropriate areas.		
21.	<b>Basement/Lower Parking</b> to be used only for Parking and Nonflammable stores as per DC Rule CI.15.11.12 & 15.11.13. Human habitation use of any kind is not permitted.		
22.	<b>Adequate Ventilation arrangement to be provided for Hotel Kitchen room areas.</b>		
23.	Open Terrace, especially over topmost floor of the building should not be covered or taken into use for any Hotel, Business, commercial purposes or human habitation such as any Roof Top Structure or alike.		
24.	(a) <b>ABC Type Fire Extinguishers</b> ,6 kg cap.(ISI mark of Reputed Brand) - 2 Nos. on every floor and additional 1Nos for Electric Panel Board, 1 Nos for Lift Room of each building and 1 Nos for D.G. Set /Transformer/D.P/ Feeder pole to be provided. (b) ABC Type 6 kg cap.(ISI mark of Reputed Brand) -1 Nos. minimum for every Classroom/shop/office, etc to be provided in case of Mix or Commercial occupancy bldgs. (c) ABC Type 6 kg capacity (ISI mark of Reputed Brand) -1 Nos. minimum for every 100 sq mtr area for every Basement or other Parking areas AND 1 no for every vehicle for bldgs. having Stack Mechanical/Puzzle Parking if any. (d) ABC Type 2 kg capacity (ISI mark of Reputed Brand) -1 Nos. minimum for every Flat. (e) (i) <b>Modular type Fire Extinguisher</b> ,5 kg cap - 1 Nos to be provided in flat kitchens for Residential Buildings more than 60 m in height and 1 no over top of every upper car for Mechanical/Puzzle area Parking, if any. (ii) <b>Modular FE - 10 KG</b> capacity to be provided for each laboratory area. (iii) <b>Modular FE - 10 KG</b> capacity to be provided over Indoor Transformers given under roof(covered slab) (f) (i) <b>Automatic Fire Trace &amp; Suppression System</b> to be provided for Computer Server Rooms. (ii) <b>Automatic Fire Suppression System</b> to be provided over Kitchen Hoods Ducts for Kitchens for Hotels.		
25.	a) <b>Courtyard Ring Mains (Above Ground) and or Parking Hydrants</b> with one 2/4 way Collecting Head for each wing to be provided apart from the Bldgs in front, at accessible position as per IS-13039-1991 - Provision & Maintenance of External Hydrant System. b) <b>Fire Hydrant Valve</b> should be installed on each 'Riser cum Down Comer' With Delivery Hose/Hoses Box including Fire Nozzle/Branch (ISI Mark) on each floor of each building of any type of occupancy including each parking floor i.e. All basements, Lower/ ground/ upper/ podium/ parking under raised open space/multilevel parking. c) <b>Fire service inlet to be provided at the main gate.</b>		
26.	<b>Fire Pump Installation</b> and all Emergency Lighting System (eg. Staircase, passage, etc to be connected to <b>Independent Backup System</b> , for cluster and Tower Buildings.		
27.	a) <b>LPG Reticulated System (Gas Bank)</b> installation is preferred on ground level from fire safety point in High		



Tejasvi Education Trust  
 Chairman Secretary Treasurer

3.5kg a point

	Rise/Educational Building. It shall comply with ISI 6044 - 1988 Code and OISD norms. Modular Fire Ext. 10 kg - 1 No for each Gas bank, (up to 500 kg -1 No and >500 kg -2 Nos) ABC Type Fire Ext. (ISI mark) - 6 kgs - 5 Nos. b) LP Gas detection system to be installed in the Chemistry Laboratory.
28.	Heat and or Smoke /Multi Sensor Detectors with Response Indicators (RI) to be provided for entire False Ceilings and coverings if any.
29.	a) Fire Evacuation Plan/Fire Orders to be prepared for Special Buildings with proper display of adequate Directional Illuminated Signage's and Exit Drawings boards, etc. b) Lightning Arresters (As per IS 3070-3 (1993)) to be provided on top of bldgs. above 36 mts. for Lightning safety.
30.	Hotels, Hospitals, Malls and other special/commercial buildings to install LP Gas Detector Devices in their kitchens.
31.	All Three Star & above Starred Hotels, Hospitals above 100 beds, Malls and other special/commercial buildings to install Fire Stop Curtains of minimum 2 hrs resistance in passages, etc at strategic locations.
32.	i) Addressable Automatic Smoke/Multi Sensor Detection and Fire Alarm System to be provided for height more than 30 Mtrs of Educational Buildings as per IS-2189-1999 Code of Practice for selection, installation and maintenance of Automatic Fire Detection and Alarm System. Detectors and Panel Board to be of reputed company. Linear Heat Detection System for Electrical/Electronic Panels/Computer Server, etc ii) Addressable Automatic Smoke/Multi Sensor Detection and Fire Alarm System to be provided for all laboratory area, Multi-Purpose hall/Auditorium area. iii) Laser Beam Detectors to be provided for all Multipurpose hall/Auditorium area.
33.	Starred Hotels, Hospitals above 100 beds, Malls, Multiplexes and other special/commercial/Educational buildings should apply Fire Retardant Paint for Electric Cables and Pipes, etc
34.	Hotels, Hospitals, Malls, Multiplexes, Industrial special bldgs above 15 mtrs height of individual proprietorship to install Cloud based Remote Monitoring and Alert Notification System (Feeds) for their entire Fire Fighting Installation connected to PCMC Fire Brigade Control Centre.
35.	Full equipped Fire Control Room be provided on Ground floor with qualified Fire Officer appointment for Special Bldgs like Hotels, Malls, Multiplexes, Hospitals, etc above 30 mtrs and or recommended by fire dept.
36.	Fire Installation to be got done from the authorized Licensed Agency of Govt. of Maharashtra only and Drawings for Tower buildings above 40 mtrs height, Commercial Complexes Malls, Multiplexes, Hospitals above 100 beds, Star Hotels etc. to be got approved, from local fire authority before starting of work.
37.	Building Revision if any towards Remaining/Addl FSI, TDR Loading, Addl Plot Amalgamation, etc. in future, shall be sanctioned, subject to strict compliance of PCMC DC Rules Cl.6.2.6.1, 10.6, 19.6.2, 19.6.3, 19.6.4 and GR No.TPS-1809/287/CR-1924/UD-13, Dt.10/03/2010, for Two Staircases, proper Side Margins & proper Approach Road width clearance, only. Apart from above requirements, the construction of the building and compliance to be carried out as per the following codes, which is the moral responsibility of the applicant - a. NBC -2016 Codes - Part IV - Fire and Life Safety b. ISI Codes - <ul style="list-style-type: none"> <li>• IS-1642 - Code for Fire Safety of Buildings.-Details of Construction</li> <li>• IS-1643 - Code for Fire Safety of Buildings- Exposure Hazard.</li> <li>• IS-1644 - Code for Fire Safety of Buildings- Exit requirement and Personal Hazards.</li> <li>• IS-1646 - Code for Fire Safety of Buildings- Electrical Installation.</li> <li>• IS-732 - Code for Electrical Wiring installations.</li> <li>• IS-1893- Criteria for Earthquake Design of Structures and</li> <li>• IS-4326- Code for Earthquake Resistance Design and Construction of building</li> <li>• IS-2309- Code for Protection of buildings against Lightning Safety.</li> </ul>
NOC Applicable Points Nos.:	1, 2, 4, 5, 6, 7, 8, 9 (a, b), 11, 12, 13, 18, 19, 20, 21, 23, 24 (a, b, c, e(ii,iii), f (i)), 25, 26, 27, 28, 29, 32, 33, 36, 37 Only.
NOC Remarks if any	Rev to Prov Fire NOC No. Fire/01/5PC/WS/978/2022 Dt. 24/11/2022 Subject to Sanctioned Plan No. BP/Borhadewadi/34/2023 Dt. 20/04/2024 As per Proposal Note No. 2196 Sanctioned By Hon. Addl. Commissioner on Dt. 02/08/2024

Since, this NOC is only for building construction purposes, Fire NOC for the Business / Utility purposes should be taken separately. Eg. Malls, Multiplexes, Hotels, Hospitals, Schools, Gas Banks, Gas Agencies, Petrol Pumps, etc.

This NOC is a guideline, based/framed on present codes/rules/conditions, to carry out / provide / install fire equipment's and installation as per governing rules. However, practical technical working, designing and actual implementation may require additions to fire equipment, etc depending upon the actual site conditions during/after the construction and or the rules prevailing during that time. The concerned Fire Consultants / Fire Licensing Agency / MEP Consultants / Project Management Consultants / etc should work out on pure technical grounds. The Fire Equipments, Systems to be installed should be of high standard, having ISI, LPCB, UL, NFPA, EN, CE, etc standards.

This NOC to be read carefully and note to be taken of all the "Applicable Points" mentioned above. All applicable points/conditions to be fulfilled and fire installations to be installed before the submission of Final Fire NOC. The Fire Fighting System installation to be got done by actual Licensed Fire Agency only, and the Fire Installation Certificate (AMC) in Form 'A' as per Sec.3(3) of Maharashtra Fire & Life Safety Act - 2006, to be submitted at the time of Final NOC.

Difference of fees amount if any, found during Audit, in future, will be recovered from the Applicant/ Occupier.

Fire NOC Fees once paid, is Non-refundable.

This is a temporary NOC, issued only for plan sanctioning of the buildings and layout purposes, from fire prevention point of view. This NOC should not be treated as a Permission. This Fire NOC doesn't imply any clearance of matter. Necessary Permissions and Clearances to be sought from the concerned Building Permission/Town Planning, Aviation, MPCB, Defense, Collector's office etc. as applicable.

**PRINCIPAL**  
GLOBAL ACHIEVERS SCHOOL  
MOSHI, PUNE-412109

**Tejasvi Education Trust**  
Chairman Secretary Treasurer

Fire Department reserves the right to alter, modify, revise or revoke the NOC.


All other rules governing of this department and or changes, up-gradation in equipment/installation are applicable from time to time.

Any false or wrong information or documents given knowingly or unknowingly or manipulated, or precautions mentioned above if not adhered will be liable for cancellation / revoking of the NOC as per Cl.386(3) of MMC Act -2012 and the applicant will be solely responsible for the matter and will be liable for legal action. NOC Fees once paid, shall not be refunded.

NOC issued, subject to final approval from Building Permission Dept. of PCMC.

(Abbrev : B-Basement, Gr-Ground, Stl- Stilt, Flr-Floor, Po-Podium, Pr-Parking, PoPr-Podium Parking, BP-Basement Parking, UBP- Upper Basement Parking, LBP- Lower Basement, GP-Ground Parking, LGP - Lower Ground Parking, UGP - Upper Ground Parking)

Proposed Site Address -  
S.No. 272/1/3 Borhadewadi, Pune.



Fire Officer  
Pimpri Chinchwad Municipal Corporation  
Pimpri, Pune - 411018

To,  
M/s. Tejasvi Education Trust  
M/s. Sumann Associates  
Arch. Nitin Chavan,

Owner/Through - M/s. Tejasvi Education Trust

Particulars	Previous NOC No Dt.	NOC Fees Paid (Rs.)	Receipt No. & Date
Paid For Prov	Fire/01/SPC/WNS/978/2022 Dt. 24/11/2022	755600/-	R.No. 303322230020415 Dt. 24/11/2022
Paid For CFC	NA	1500/-	R.No. 303324250006322 Dt. 03/06/2024
	Total	757100/-	

Diff Amount for Rev Fire NOC Rs. Nil

\* Fees Receipt to be preserved properly & Xerox copy submitted during next submission for Revision or Final NOC case.

\*\*\*\*\* FINISH \*\*\*\*\*



**PRINCIPAL**  
GLOBAL ACHIEVERS SCHOOL  
MOSHI, PUNE-412105

**Tejasvi Education Trust**

**Chairman Secretary Treasurer**



**PIMPRI CHINCHWAD MUNICIPAL CORPORATION, PIMPRI - 18  
FIRE DEPARTMENT**

File No:- **978**

O.W.No:- Fire/01/SPC/WS/978/2022.

Date:- 24/11/2022

**Provisional Fire No Objection Certificate for Building Construction**

Token No:- 103319200012723

Token Dt:- 02/11/2022

With reference to the application and Plans submitted, Dt. 02/11/2022 by the under mentioned applicant, technical site inspection had been carried out by the concerned Officer of the fire department in accordance with the submitted plan copies and documents.

Revised Fire NOC is being herewith issued under Rule 6.2.6.1; 6.7.2 & 19, and other applicable rules of Development Control Rules of PCMC, NBC 2016 - Part IV, G.R.Dt.10/03/2010, and under Sec 3(2) of Maharashtra Fire & Life Safety Act 2006 & Rules 2009, at the under mentioned site, subject to compliance of the following conditions.

**Proposed Site Address -**

S.No.272/1/3,  
Borhadewadi, Pune.

Plot Area	3300.00	Sq.Mtrs
Permissible FSI Area (Incl. Ancillary FSI)	2722.50	Sq.Mtrs

**Building Details -**

Bldg. Nos.	Height (From GI to Slab)	No. of Floors	Net Built up Area (Sq.Mtrs)	Gross Built up Area (Sq.Mtrs)	Occupancy Use Type	Bldg. Classification
One	14.90	Gr+03	2329.17	2743.85	[School]	Educational

- Building Side margins, Drive ways, Staircases, Passages, Vehicle Ramps clearance as per shown in plan, for the maneuverability of the fire fighting vehicle should be kept absolutely free of obstructions, all the time. No Landscaping or any other structural work, to be done in side margins or in any other way, obstructing the access to side margins.
- Emergency Contact Numbers Board of Fire, Ambulance, Police & MSEB to be displayed prominently at main gate and other easily visible places.
- Podium If provided, should be designed and constructed to carry weight of 45 tons for Special Heavy Fire Rescue Vehicle load (ALP, TTL, etc). The required vehicular Turning Width, at Ramp ends & building corners to be provided on podium. Podium slab to be painted with Red colour strip exactly above the Beam line so as to easily identify it and ease operation of the Special Fire Vehicle Outrigger Jacking.
- Hose Reel Hose (Type-B), to be provided on all floors with shut off nozzle, (according to length of Bldg), fixed on wall Only. (Fitting of hose reel drums on Riser-Downcomer pipe is not allowed).
- Extra Standby Pump (Electric for Res. and Diesel driven as applicable) of same capacity connected to DG Set, to be installed.
- Independent Duct provision to be made for Riser cum Down Comer System for Buildings more than 7 floors and all Commercial Buildings.
- Over Head RCC Fire Water Tank - 10,000 ltrs for Buildings up to 24 Mtrs height, 25,000 ltrs for buildings from 24 to 70 Mtrs height as well for Special/Non Res.Bldgs. Tank capacity varies depending upon type of occupancy of building.
- Under Ground RCC Fire Water Tank - 50,000 ltrs capacity for Buildings above 24 mtrs to 40 mtrs height. 75,000 ltrs capacity for Buildings from 40 mtrs to 60 mtrs & 1,00,000 ltrs. capacity for Buildings 60 to 70 mts. height and for Special/Non Res.Bldgs. Tank capacity varies depending upon type of occupancy of building. However for group (cluster) of maximum 5 buildings, fire Water tank if single, its capacity should be calculated on the basis of 2250 lpm for minimum 2 hours of fire fighting or min 50% of the total water requirement for all buildings, whichever is higher.
- (a) Down Comer System - 4" dia, C class ISI mark GI pipe, 3 to 5 HP Terrace pump with ISI mark accessories for each Bldg. /Wing upto 24 mts height, with Hose Reels on all floors to be provided with fire service inlet at accessible position.  
(b) Riser cum Down Comer System (each Bldg/Wing) - 6" dia, C class, ISI mark GI pipe, UG Tank Pump to be of Coupled Type, Positive Pressure Operating and above capacity for group/cluster of buildings (5 Wings and above) based on calculation with Hose Pipes (according to length of Bldg), Hydrant Valves, Nozzle, fittings, Starter, Pressure Switches, DOL Switch, etc. to be ISI Mark for all bldgs and provided with Fire Service Inlet at accessible position.  
For Bldgs above 60 mtrs, UG Tank Pump to be of Multi Head, Multi Outlet type. Automatic Sprinkler installation if any, to be provided with independent Pump of rated output and capacity. Jockey Pump of rated capacity to be provided for Wet/Sprinkler system, etc.

Height of Bldg (Mtrs)	OH Tank Pump Cap.	UG Tank Pump Cap.	Head (UG Pump)
(i) 24 to 40 mts	900 lpm	1800 lpm	90 mts
(ii) 40 to 60 mts	900 lpm	2280 lpm	110 mts
(iii) 60 to 70 mts	900 lpm	2280 lpm	120 mts

**Tejasvi Education Trust**

**GLOBAL ACHIEVERS SCHOOL**  
MOSHI, PUNE - 412105.

Chairman Secretary Treasurer

28. 11
10. Automatic Sprinkler System to be provided for
    - (a) All types of Bldgs. having Basements/Lower Parking area more than 200 sq.mt.
    - (b) All Multilevel Basements.
    - (c) All Covered Ground and all Upper floor (multilevel) Stilt parking.
    - (d) All Podium Parking (Below Podium / all parking under elevated open spaces on podium).
    - (e) All Mechanical / Puzzle / Stack Parking as Side Wall Sprinklers diagonally fitted on opposite sides of support channels of the structure.
    - (f) All Commercial Bldg with Covered Area more than 500 sq mts. ~ (For Entire building.)
    - (g) All buildings (Including Refuge Area) other than Residential, Mix and Educational of height above 15 mtrs.
    - (h) All Hotels, Hospitals, Malls, Multiplexes, Warehouses, etc with height above 15 mtrs.
    - (i) All Residential Buildings (Including Refuge Area) above 45 mtrs height to be fully sprinklered.
    - IS-15105 - Design and Installation of Fixed Automatic Sprinkler Fire Extinguishing System. Sprinkler Pump shall be independent of rated output and capacity.
    - (j) All Ground Parking Area, All Covered Parking Area, All Educational Bldg. Including passage area and multipurpose hall area.
  11. Garbage chute if any, shall be provided with independent Sprinkler system at each garbage inlet point of the chute pipe.
  12. I) MCP (Manual Call Points) and PA (Public Address ) Communication System with Talk Back facility to be provided near to the all staircase (Not allowed in Fire Ducts or Staircases)  
 II) Life Guard & C.C.T.V. surveillance camera system to be provided to the entire premises of Swimming Pool area & Educational Bldg.  
 III) Public address system to be provided for Educational Bldg or each floor of Educational Bldg. for the emergency evacuation purpose.
  13. I) Minimum Two Staircases (apart) to be provided. Two enclosed Fire Escape Staircase of Fire Tower Type to be provided with Double Leaf Fire Resistance Doors Assembly (with frame & accessories) of min 120 mins. According to the width of staircase (45mm thick) to be provided for all indoor assembly hall/Yoga/Kabbaddi hall area and Commercial bldgs to install Metal F. R. Door of CBRI / IPIRTI approved. This fire staircase shall be treated for use of inhabitants during fire and other emergencies and will not be taken into any other use, not even for installation of firefighting system, etc  
 II) Handrail to be provided for all Staircase of the Educational Building.
  14. Fire Resistance Doors as above, of min 120 mins (45mm thick) as per IS 4079 to be provided for all Flats Entrances and Balcony/Terrace opening Doors for buildings above 60 mtrs.
  15. Fire Escape Staircase to be provided with Pressurization System, for Bldgs above 60 mtrs
  16. All Bldgs above 60 mtrs and Starred Hotels, Malls, Multiplexes, Hospitals above 50 beds to be provided with Fire Sealant material of 2 hours rating at every floors at the point of Electric cables and other pipes etc passing through such floors or walls openings, etc
  17. Hotel bldgs above 24 mtrs, Hospital bldgs above 15 mtrs, other Fully Commercial Bldgs above 24 mtrs, Residential Bldgs above 45 mtrs and Malls, Multiplexes irrespective of their height to provide Fire Retardant Paint/Coat (DRDO approved) for Electrical Cables.
  18. Special Commercial bldgs like Hotels, Hospitals, Commercial Complexes, above 30 mtrs, Mix Occupancy Bldgs above 45 mtrs and fully Residential Bldgs above 60 mtrs to provide at least 1 no. of Self Rescue Chute for each building.
  19. Automatic Fire Suppression Systems to be provided for Commercial Kitchen Hoods of Hotels, Restaurants, Canteens, etc, complying LPS 1223/UL300.
  20. Among the total Lifts provided, for bldgs upto 36 mtrs height, minimum one Lift to be Fire Lift of 545 kgs (8 person) capacity. Bldgs above 36 mtrs height to be provided with Fire cum Stretcher Lift (min 1.9 m x 2.5 m). These lifts shall have Fireman's switch and Talk back Facility emergency communication system
  21. Refuge Area of minimum 1/4th of the maximum floor area to be provided in front & conspicuously marked for identification located after 24 mtr, 39 mtr and every 5th floor thereafter. Refuge Area parapet wall and railings to be painted in red colour and a bold "Fire Refuge Area" Board of min. 5ft x 3 ft painting prominently to be displayed. Fire Resistance Door (with frame & accessories) of min 120 mins (45mm thick) to be fitted for Refuge Area.
  22. a) Basement/Lower Parking should have proper Mechanical Smoke Extraction & Dewatering pump Arrangements to prevent smoke and water logging.  
 b) Mirror should be provided all Basement/Lower/Ground/Upper Parking Level's blind turn appropriate areas.
  23. Basement/Lower Parking to be used only for Parking and Nonflammable stores as per DC Rule Cl.15.11.12 & 15.11.13. Human habitation use of any kind is not permitted.
  24. Adequate Ventilation arrangement to be provided for Hotel Kitchen room areas.
  25. Open Terrace, especially over topmost floor of the building should not be covered or taken into use for any Hotel, Business, commercial purposes or human habitation such as any Roof Top Structure or alike.
  26. (a) ABC Type Fire Extinguishers .6 kg cap. (ISI mark of Reputed Brand) - 2 Nos. on every floor and additional 1 Nos for Electric Panel Board, 1 Nos for Lift Room of each building and 1 Nos for D.G. Set /Transformer/D.P/ Feeder pole to be provided.  
 (b) ABC Type 6 kg cap. (ISI mark of Reputed Brand) - 1 Nos. minimum for every Classroom/shop/office, etc to be provided in case of Mix or Commercial occupancy bldgs.  
 (c) ABC Type 6 kg capacity (ISI mark of Reputed Brand) - 1 Nos minimum for every 100 sq mtr area for every Basement or other Parking areas AND 1 no for every vehicle for bldgs. having Stack Mechanical/Puzzle Parking if any.  
 (d) ABC Type 2 kg capacity (ISI mark of Reputed Brand) - 1 Nos. minimum for every Flat.  
 (e) (i) Modular type Fire Extinguisher, 5 kg cap - 1 Nos to be provided in flat kitchens for Residential Buildings more than 60 m in height and 1 no over top of every upper car for Mechanical/Puzzle area Parking, if any  
 (ii) Modular FE - 10 KG capacity to be provided for each laboratory area.  
 (iii) Modular FE - 10 KG capacity to be provided over Indoor Transformers given under roof (covered slab)  
 (f) (i) Automatic Fire Suppression System to be provided for Computer Server Rooms  
 (ii) Automatic Fire Suppression System to be provided over Kitchen Hoods Ducts for Kitchens for Hotels

Chairman Secretary Treasurer

Principal  
 GLOBAL ACHIEVERS SCHOOL  
 Page 2 of 4 - 412105.

27.	i) Courtyard Ring Mains (Above Ground) and or Parking Hydrants with one 2/4 way Collecting Head for each wing to be provided apart from the bldg in front, at accessible position as per IS-13039-1991 - Provision & Maintenance of External Hydrant System. ii) Fire service Inlet to be provided at the main gate.
28.	Fire Pump Installation and all Emergency Lighting System (eg. Staircase, passage, etc to be connected to Independent Backup System, for cluster and Tower Buildings.
29.	a) LPG Reticulated System (Gas Bank) installation is preferred on ground level from fire safety point in High Rise/Commercial Building. It shall comply with ISI 6044 - 1988 Code and OISD norms. Modular Fire Ext. 10 kg - 1 No for each Gas bank, (up to 500 kg - 1 No and >500 kg - 2 Nos) ABC Type Fire Ext. (ISI mark) - 6 kgs - 5 Nos. b) LP Gas detection system to be installed in the Comm. Kitchen area/Restaurant.
30.	Heat and or Smoke /Multi Sensor Detectors with Response Indicators (RI) to be provided for entire False Ceilings and coverings if any.
31.	a) Fire Evacuation Plan/Fire Orders to be prepared for Special Buildings with proper display of adequate Directional Illuminated Signage's and Exit Drawings boards, etc. b) Lightning Arresters (As per IS 3070-S (1993)) to be provided on top of bldgs. above 36 mts. for Lightning safety.
32.	i) Addressable Automatic Smoke/Multi Sensor Detection and Fire Alarm System to be provided for Commercial/Educational Buildings above 15mtrs height or having floor area above 500 sq.mtrs, with Laser Beam Detectors in Malls, Godowns, Auditoriums, Multiplexes, Educational Bldg. & all other building, including Residential bldgs. above 45 Meter in height as per IS-2189-1999 Code of Practice for selection, installation and maintenance of Automatic Fire Detection and Alarm System. Detectors and Panel Board to be of reputed company. Linear Heat Detection System for Electrical/Electronic Panels/Computer Server, etc ii) Addressable Automatic Smoke/Multi Sensor Detection and Fire Alarm System to be provided for all laboratory area, Multi-Purpose hall/Auditorium area. iii) Laser Beam Detectors to be provided for all Multipurpose hall/Auditorium area.
33.	Hotels, Hospitals, Malls and other special/commercial buildings to install LP Gas Detector Devices in their kitchens.
34.	All Three Star & above Starred Hotels, Hospitals above 100 beds, Malls and other special/commercial buildings to install Fire Stop Curtains of minimum 2 hrs resistance in passages, etc at strategic locations.
35.	Starred Hotels, Hospitals above 100 beds, Malls, Multiplexes and other special/commercial/Educational buildings should apply Fire Retardant Paint for Electric Cables and Pipes, etc
36.	Hotels, Hospitals, Malls, Multiplexes, industrial special bldgs above 15 mtrs height of individual proprietorship to install Cloud based Remote Monitoring and Alert Notification System (Feeds) for their entire Fire Fighting Installation connected to PCMC Fire Brigade Control Centre.
37.	Full equipped Fire Control Room be provided on Ground floor with qualified Fire Officer appointment for Special Bldgs like Hotels, Malls, Multiplexes, Hospitals, etc above 30 mtrs and or recommended by fire dept.
38.	Fire Installation to be got done from the authorized Licensed Agency of Govt. of Maharashtra only and Drawings for Tower buildings above 40 mtrs height, Commercial Complexes Malls, Multiplexes, Hospitals above 100 beds, Star Hotels etc. to be got approved, from local fire authority before starting of work.
39.	Building Revision if any towards Remaining/Addl FSI, TDR Loading, Addl Plot Amalgamation, etc. in future, shall be sanctioned, subject to strict compliance of PCMC DC Rules Cl.5.2.6.1, 10.6, 19.6.2, 19.6.3, 19.6.4 and GR No.TPS-1809/287/CR-1924/UD-13, Dt.10/03/2010, for Two Staircases, proper Side Margins & proper Approach Road width clearance, only. Apart from above requirements, the construction of the building and compliance to be carried out as per the following codes, which is the moral responsibility of the applicant - a. NBC -2016 Codes - Part IV - Fire and Life Safety b. ISI Codes - • IS-1642 - Code for Fire Safety of Buildings.-Details of Construction • IS-1643 - Code for Fire Safety of Buildings- Exposure Hazard. • IS-1644 - Code for Fire Safety of Buildings- Exit requirement and Personal Hazards. • IS-1646 - Code for Fire Safety of Buildings- Electrical Installation. • IS-732 - Code for Electrical Wiring Installations. • IS-1893- Criteria for Earthquake Design of Structures and • IS-4326- Code for Earthquake Resistance Design and Construction of building • IS-2309- Code for Protection of buildings against Lightning Safety.
NOC Applicable Points Nos.:	1, 2, 4, 7, 9 (a), 10 (c, j), 12 (i) (ii) (iii), 13 (i) (ii), 20, 25, 26 (a, b, c, e(iii), f (i)), 27 (i) (ii), 28, 30, 31 (a), 32 (i) (ii) (iii), 38, 39 Only.
NOC Remarks if any	Subject to DP Opinion No. TPD/WS/Bo.Wadi/421/2020, Dt.31/12/2020. As per proposal sanctioned note No. 2281, Dt.18/11/2022 by Hon. Commissioner.

Since, this NOC is only for building construction purposes, Fire NOC for the Business / Utility purposes should be taken separately., Eg. Malls, Multiplexes, Hotels, Hospitals, Schools, Gas Banks, Gas Agencies, Petrol Pumps, etc.

This NOC is a guideline, based/framed on present codes/rules/conditions, to carry out / provide / install fire equipments and installation as per governing rules. However, practical technical working, designing and actual implementation may require additions to fire equipment, etc depending upon the actual site conditions during/after construction. The concerned Fire Consultants / Fire Licensing Agency / MEP Consultants / Project Management Consultants / etc should work out on site.

Chairman Secretary Treasurer

GLOBAL ACHIEVERS SCHOOL  
MOS Page 3 of 4 12105

grounds. The Fire Equipments, Systems to be installed should be of high standard, having ISI, LPCB, UL, NFPA, EN, CE, etc standards.

This NOC to be read carefully and note to be taken of all the "Applicable Points" mentioned above. All applicable points/conditions to be fulfilled and fire installations to be installed before the submission of Final Fire NOC. The Fire Fighting System Installation to be got done by actual Licensed Fire Agency only, and the Fire Installation Certificate (AMC) in Form 'A' as per Sec.3(3) of Maharashtra Fire & Life Safety Act - 2006, to be submitted at the time of Final NOC.

Difference of fees amount if any, found during Audit, in future, will be recovered from the Applicant / Occupier.

Fire NOC Fees once paid, is Non-refundable.

This is a temporary NOC, issued only for plan sanctioning of the buildings and layout purposes, from fire prevention point of view. This NOC should not be treated as a Permission. This Fire NOC doesn't imply any final clearance of matter or should not be taken as granted for clearance of building permission. Necessary Permissions and or Clearances to be sought from concerned Building Permission/Town Planning, Aviation, MPCB, Defense, Collectorate office, etc Depts as applicable.

Fire Dept reserves the right to alter, modify, revise or revoke the NOC.

All other rules governing of this department and or changes, up-gradation in equipment/installation are applicable from time to time.

Any false or wrong information or documents given knowingly or unknowingly or manipulated, or precautions mentioned above if not adhered will be liable for cancellation / revoking of the NOC as per CI.386(3) of MMC Act -2012 and the applicant will be solely responsible for the matter and will be liable for legal action. NOC Fees once paid, shall not be refunded.

NOC issued, subject to final approval from Building Permission Dept. of PCMC.

(Abbvr: B-Basement, Gr-Ground, Stl- Stilt, Flr-Floor, Po-Podium, Pr-Parking, PoPr-Podium Parking, BP- Basement Parking, UBP- Upper Basement Parking, LBP- Lower Basement, GP-Ground Parking, LGP - Lower Ground Parking, UGP - Upper Ground Parking)

  
Fire Officer

Pimpri Chinchwad Municipal Corporation  
Pimpri, Pune-411018.

To,

Mr. Aniruddha Dandekar / Arch. Nitin Chavan

Owner/ Through: M/s. Tejasvi Education Trust

Particulars	Previous NOC No. & Date	NOC Fees Paid (Rs.)	Receipt No. & Date
Paid for CFC	N/A	1,500/-	R.No.303321220001901, Dt.18/05/2021
Diff. Amt. Paid	N/A	7,54,100/-	R.No.303322230020415, Dt.24/11/2022
	Total Paid	7,55,600/-	

Diff. Amt. For Provisional Fire NOC Fees Rs.7,54,100/- paid.

\* Fees Receipt to be preserved properly & Xerox copy submitted during next submission for Revision or Final NOC case.

FINISH

  
Tejasvi Education Trust

Chairman Secretary Treasurer

  
PRINCIPAL  
GLOBAL ACHIEVERS SCHOOL  
MOSHI, PUNE - 412105.