



Pimpri Chinchwad Municipal Corporation  
Pimpri , Pune – 411018.  
Phone :- 020- 67331110/1120  
Fax :- 020- 27425600  
E-Mail :- commissioner@pcmcindia.gov.in  
Web :- www.pcmcindia.gov.in

---

NO – ws/lab/1228/2025

Date – 13/05/2025

To

The Principal,  
Global Achievers School,  
Moshi.

**Subject: Water sample Potability Certificate.**

Drinking water sample provided by Global Achievers School, Moshi. on Date: 06/05/2025 was analysed for Chemical and Bacteriological analysis. As per the analysis reports no. ws /lab /1209/2025 dated 07/05/2025 & ws /lab /1219/2025 dated 10/05/2025 the water Samples are safe for drinking purpose.

The Bacteriological & chemical analysis reports are attached herewith.

**Note-The water sample not drawn by this laboratory**

Chief Chemist  
Pimpri Chinchwad Municipal Corporation  
Pimpri -18

# PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION

## REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER



No-WS/LAB/1219/2025

Date - 10 / 05 / 2025

DATE OF EXAMINATION - 06 / 05 / 2025

NAME - ग्लोबल अचिव्हर्स स्कुल

ADDRESS - मोर्शी

SOURCE - R.O Water.

SR.NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUSION MPN/100ml		REMARK
			Coliforms	E.Coli	
1	Water Sample	Nil	0/100ml	-	Potable.
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					

CHIEF CHEMIST

Water Treatment Plant  
Pimpri Chinchwad Municipal Corp.  
Noida, Pune 44

# PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION



## REPORT OF CHEMICAL EXAMINATION OF WATER

NAME - डलवल अरिक्लरु सुकुल

No-WS/LAB/1209/2025.

ADDRESS - डोरुी.

Date - 07 / 05 / 2025.

SOURCE - R.O Water.

Date of Receipt - 06 / 05 / 2025.

Date of Examination - 06 / 05 / 2025

Sr.No.	Tests	I. S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N. T. U. Max	0.81 NTU.	/	
2	pH	6.5 to 8.5	7.91		
3	Total Hardness (as CaCO <sub>3</sub> )	200 mg/lit	88 mg/lit		
4	Chloride	250 mg/lit	28 mg/lit		
5	Calcium	75 mg/lit	16.03 mg/lit		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY

CHIEF CHEMIST

WATER TREATMENT PLANT, NIGDI, PCMC